

ATTESTATION OF CONFORMITY

ATTESTATO DI CONFORMITA'

Attestation number

Attestato numero : 3502387.02

Issued to

Rilasciato a : Power-One Italy S.p.a.
Via S. Giorgio 642
I-52028 Terranuova Bracciolini (AR)
Italy

Manufacturer
Costruttore

: Power-One Italy S.p.a.
Via S. Giorgio 642
I-52028 Terranuova Bracciolini (AR)
Italy

Product Type

Tipo prodotto : Photovoltaic grid tied inverter

Model reference

Riferimento Modello : MICRO-0.3-I-OUTD-230;
MICRO-0.25-I-OUTD-230; MICRO-0.25-I-OUTD-230-ACPV

Firmware release

Revisione firmware : DSP: B1.58 Checksum 0X468E

Testing Laboratory

Laboratorio prove : DEKRA at Power-One Italy S.p.a. ,
Via S. Giorgio 642,
I-52028 Terranuova Bracciolini (AR)
Italy

Test report No.

Rapporto Nr. : 3502387.51

Requirements

Requisiti : EN 50178:1997

Remarks

This Attestation of Conformity replaces the DEKRA AoC having same number and dated 05 September, 2013.
Questo Attestato di Conformita' sostituisce l' attestato DEKRA avente stesso numero e datato 05 Settembre, 2013

This Attestation covers the following alternative changes in construction:

Questo Attestato copre le seguenti alternative nella costruzione:

- Optional use of Extended assembly wiring, by Amphenol LTW, model SPS-03AMFM-LL7CXX, where XX is a two digit figure denoting assembly length (3 to 5 meters), C denotes the type of cable and maybe D for HAR type cable or E for 2Pfg 1940 type cable (XLPO jacket). Rated 300 Vac, 5 A, -40 to +90 °C.
To be connected to the AC Output cable (AC Output wiring harness), One side of the mentioned extended assembly cable terminates with receptacle (Plug) 3 positions with female pins the other side terminates with free wiring.
Local Electrical codes should be taken into consideration during installation of the equipment incorporating the extended assembly wiring.
- Use of alternative DC connector (+) Multicontact MC4 Series (model PV-ADSP4-S2-UR/6) rated 1000 Vdc, 30 A;
- Use of alternative DC connector (-) Multicontact MC4 Series (model PV-ADBP4-S2-UR/6) rated 1000 Vdc, 30 A;
- Use of the following alternative PWB: ZGN.V0J06.0 or ZGN.V0J06.1;
- Use of alternative electrical rating for operating frequency: 50/60 Hz.
- Use of alternative Trade-Mark ABB
- Editorial correction of operating temperature range

Component list of report 3502387.51 has been updated.

La lista dei componenti critici del rapporto 3502387.51 è stata aggiornata

The undersigned declares that the above described product meets the above mentioned technical specification. This attestation of conformity is issued based on the test results as laid down in the referred Test Report . The investigation does not include an assessment of the manufacturer's production.

Il sottoscritto dichiara che il prodotto di cui sopra è conforme ai requisiti tecnici menzionati. Questo attestato di conformità è rilasciato sulla base dei risultati di prova riferiti nel rapporto sopra menzionato.

La valutazione non include una verifica del luogo di produzione.

3502387.02

If a DEKRA Authorization to apply the DEKRA VERIFIED INVERTER seal has been issued by DEKRA on the subject product, this attestation of conformity authorizes the manufacturer to make reference to the "Requirements" object of this attestation, inside the DEKRA VERIFIED INVERTER seal .

Se il prodotto in oggetto è licenziatario di un' autorizzazione DEKRA all'uso del sigillo DEKRA VERIFIED INVERTER, il presente attestato di conformità autorizza il costruttore a fare riferimento ai "Requisiti " in questo attestato, all'interno del sigillo DEKRA VERIFIED INVERTER.

Date of issue
Emesso in data : 2014/02/28



Franco Vasta
Certification manager