

ENA Engineering Recommendation G99-1 Amd.4 Type Verification Test Report

Type Approval and manufacturer/supplier declaration of compliance with the requirements of Engineering Recommendation G99-1 Amd.4	
Type Test reference number	PVS-60-TL; PVS-60-TL-S; PVS-60-TL-SX; PVS-60-TL-SX2 PVS-50-TL; PVS-50-TL-S; PVS-50-TL-SX; PVS-50-TL-SX2
Generating Unit technology	Solar Grid Tied Inverter
System Supplier name	Fimer S.p.A.
Address	Via Tortona, 25, 20144 Milano (MI) Italy
Tel. +39 055 91951	Email: Refer to www.fimer.com Web site: www.fimer.com
Maximum / Nominal rated capacity	Connection option
	PVS-60-TL; PVS-60-TL-S; PVS-60-TL-SX; PVS-60-TL-SX2 Maximum / Nominal rated capacity: 66.0 Kw / 60.0 Kw (three phases) PVS-50-TL; PVS-50-TL-S; PVS-50-TL-SX; PVS-50-TL-SX2 Maximum / Nominal rated capacity: 55.0 Kw / 50.0 Kw (three phases)
<p>We, Fimer S.p.A., as manufacturer/supplier of Generating Unit, certifies that all products manufactured/supplied by the company with the above Type Test reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the products meet all the requirements of G99-1 Amd.4.</p> <p>Attachment: Extract of Test Report Ref. 28111830 022, released by TÜV Rheinland.</p>	

Terranuova Bracciolini, 19 January 2021



Alessandro Rossi
(Testing & Laboratory Manager)



Paolo Casini
(Chief Technical Officer)

FIMER S.p.A.

HQ & Manufacturing Unit: Via J.F. Kennedy – 20871 Vimercate (MB) – Italy
 Manufacturing Unit: Via San Giorgio 642 – 52028 Terranuova B.ni (AR) – Italy
 Registered Office: Via Tortona 25 – 20144 Milano – Italy
 C.C.I.A.A. Milano/ C.F.09286180154 – REA MI – 2609050
 VAT 01574720510 – Cap. Soc. € 22.000.000,00 i.v

T +39 039 98.98.1
 T +39 055 91.95.1
www.fimer.com