



1/1 Ref. PVS-60(50)-TL (Power-One_EREK G99-1 AMD4 Type Verification Test Report)

ENA Engineering Recommendation G99-1 Amd.4 Type Verification Test Report

Type Approval and manufacturer/supplier declaration of compliance with the requirements of Engineering Recommendation G99-1 Amd.4		
Type Test reference number	PVS-60-TL; PVS-60-TL-S; PVS-60-TL-SX; PVS-60-TL-SX2 PVS-50-TL; PVS-50-TL-S; PVS-50-TL-SX; PVS-50-TL-SX2	
Generating Unit technology	Solar Grid Tied Inverter	
System Supplier name	Power-One Italy S.p.A.	
Address	Via S. Giorgio, 642 52028 Terranuova Bracciolini (AR) - Italy	
Tel. +39 055 91951	Email: http://solar.fimer.com/contact-fimer-support Email: info.italy@fimer.com	Web site: www.fimer.com
Maximum / Nominal rated capacity	Connection option	
	PVS-60-TL; PVS-60-TL-S; PVS-60-TL-SX; PVS-60-TL-SX2 Maximum / Nominal rated capacity: 66.0 Kw / 60.0 Kw (three phases) PVS-50-TL; PVS-50-TL-S; PVS-50-TL-SX; PVS-50-TL-SX2 Maximum / Nominal rated capacity: 55.0 Kw / 50.0 Kw (three phases)	
We, Power-One Italy S.p.A., as manufacturer/supplier of Generating Unit, certifies that all products manufactured/supplied by the company with the above Type Test reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the products meet all the requirements of G99-1 Amd.4.		
Attachment: Extract of Test Report Ref. 28111830 022, released by TÜV Rheinland.		

Terranuova Bracciolini, 26 March 2020


Alessandro Rossi
(R&D Project Manager)


Paolo Casini
(Chief Technical Officer)