

**C E R T I F I C A T E**  
of Conformity



**Registration No.:** AK 60157224 0002

**Report No.:** IT21CKRX 001

**Holder:** FIMER S.p.A.  
VIA TORTONA 25  
20144 MILAN MI  
Italia

**Product:** Electrical Equipment  
Grid tied inverter

**Identification:** TRIO-8.5-TL-OUTD-400 , TRIO-8.5-TL-OUTD-S-400  
TRIO-7.5-TL-OUTD-400 , TRIO-7.5-TL-OUTD-S-400  
TRIO-5.8-TL-OUTD-400 , TRIO-5.8-TL-OUTD-S-400

**Remark:**

Loss of Main Protection compliance with G59/3/09.13  
requirements (trip time doesn't exceed 1,0 s)

**Tested acc. to:** G99-1

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

**Date** 11.08.2021



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**