

C E R T I F I C A T E
of Conformity



Registration No.: AK 60157223 0001

Report No.: IT21CKRX 002

Holder: FIMER S.p.A.
VIA TORTONA 25
20144 MILAN MI
Italia

Product: Electrical Equipment
Grid tied inverter

Identification: Remark:
Loss of Mains Protection not tested

Model: TRIO-8.5-TL-OUTD-400 ; TRIO-8.5-TL-OUTD-S-400
TRIO-7.5-TL-OUTD-400 ; TRIO-7.5-TL-OUTD-S-400
TRIO-5.8-TL-OUTD-400 ; TRIO-5.8-TL-OUTD-S-400

Tested acc. to: G98-1

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 15.06.2021



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg