

**Certificate**

**BELGIUM C10/11 110%**

The results of tests performed according to reference standard BELGIUM C10/11 110% are summarized in this certificate. Power-One Italy S.p.a. declares that the units set for BELGIUM C10/11 110% operations are characterized by the following:

- The internal specification and parameters are set to be compliant with BELGIUM C10/11 110% engineering requirements.
- All units have identical internal parameters setting.
- These parameters cannot be changed without the usage of password protected tool.

**SSEG DETAILS (Small-Scale Embedded Generator)**

SSEG Type Reference:	PHOTO-VOLTAIC and EOLIC GRID TIED INVERTER
SSEG Model Reference:	UNO-2.0-I-OUTD UNO-2.0-I-OUTD-S UNO-2.0-I-OUTD-W UNO-2.5-I-OUTD UNO-2.5-I-OUTD-S UNO-2.5-I-OUTD-W
Maximum export capability (SSEG rating less parasitic load)	2750W (UNO-2.5-I-OUTD and derived models) 2200W (UNO-2.0-I-OUTD and derived models)
Nominal Output AC Power	2500W (UNO-2.5-I-OUTD and derived models) 2000W (UNO-2.0-I-OUTD and derived models)

**MANUFACTURER and TEST HOUSE DETAILS**

Name:	Power-one Italy S.p.A. - R. & D. Department
Address:	Via S. Giorgio 642, 52028 Terranuova Bracciolini - Arezzo - Italy
Telephone number:	+39-055-91951
Fax number:	+39-055-9195248
E-mail address	service@power-one.com

**TEST RESULTS SUMMARY**

Power Quality:

- Harmonic Current Emission as per EN-61000-3-2
- Voltage Fluctuation and Flickers as per EN-61000-3-3
- DC Injection as per VDE 0126
- Power Factor as per VDE 0126

Protection:

- Under/Over Frequency Tests
- Under/Over Voltage Tests
- Reconnection Times
- Loss of Mains Test

Power-One Italy S.p.a.

Terranuova Bracciolini,

September 14, 2013

Robert White  
(Director Safety & Environmental Compliance)



## BELGIUM C10/11 110% TEST RESULTS DETAILS – TYPE VERIFICATION TEST SHEET

### POWER QUALITY

(UNO-2.5-I-OUTD and derived models)								
Harmonic Current Emission as per BS EN-61000-3-2								
Harmonic	3rd [A]	5rd [A]	7rd [A]	9rd [A]	11rd [A]	13rd [A]	THD [A%]	PWHd [A%]
Limit	2.3	1.14	0.77	0.4	0.33	0.21	-	-
Test value	0.082	0.035	0.032	0.026	0.030	0.027	1.292	-

(UNO-2.0-I-OUTD and derived models)								
Harmonic Current Emission as per BS EN-61000-3-2								
Harmonic	3rd [A]	5rd [A]	7rd [A]	9rd [A]	11rd [A]	13rd [A]	THD [A%]	PWHd [A%]
Limit	2.3	1.14	0.77	0.4	0.33	0.21	-	-
Test value	0.062	0.032	0.037	0.032	0.029	0.026	1.421	-

(UNO-2.5-I-OUTD and derived models)					
Voltage Fluctuation and Flickers as per BS EN-61000-3-3					
Voltage Disturbance	Pst	Plt	D(t) > 3%	dc (%)	dmax (%)
Limit	1	0.65	0.5	3.3	4
Test Value	0.072	0.07	0.0001	0.031	0.379

(UNO-2.0-I-OUTD and derived models)					
Voltage Fluctuation and Flickers as per BS EN-61000-3-3					
Voltage Disturbance	Pst	Plt	D(t) > 3%	dc (%)	dmax (%)
Limit	1	0.65	0.5	3.3	4
Test Value	0.08	0.077	0.0001	0.013	0.447

(UNO-2.5-I-OUTD and derived models)						
VDE 0126 Limit 0.5% of 12A	DC injection [mA]			Power Factor		
	60mA, tested at three power levels			0.95 lag - 0.95 lead at three voltage levels		
Test Level	10%	50%	100%	185 Vac	230 Vac	264 Vac
Test Value	17.6	19.2	19.8	0.99	0.99	0.99

(UNO-2.0-I-OUTD and derived models)						
VDE 0126 Limit 0.5% of 10A	DC injection [mA]			Power Factor		
	50mA, tested at three power levels			0.95 lag - 0.95 lead at three voltage levels		
Test Level	10%	50%	100%	185 Vac	230 Vac	264 Vac
Test Value	17.2	17.2	19.6	0.99	0.99	0.99

## PROTECTION

(UNO-2.5-I-OUTD and derived models) and (UNO-2.0-I-OUTD and derived models)

UNDER FREQUENCY TEST						
Fnom=50Hz	BELGIUM C10/11 110% Limit	Settings			Results	
Under Frequency <	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
		47.50	0.20	47.50	0.12	47.51

OVER FREQUENCY TEST						
Fnom=50Hz	BELGIUM C10/11 110% Limit	Settings			Results	
Over Frequency >	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
		51.50	0.20	51.50	0.12	51.51

UNDER VOLTAGE TEST						
Vφ-n nom =230V	BELGIUM C10/11 110% Limit	Settings			Results	
Under Voltage <	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
	L1-N	184.0	0.20	184.0	0.16	185.9

OVER VOLTAGE TEST						
Vφ-n nom =230V	BELGIUM C10/11 110% Limit	Settings			Results	
Over Voltage > (10min AVG)	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
	L1-N	253.0	<600	253.0	<600	254.5
Over Voltage >>	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
	L1-N	264.5	0.20	264.5	0.16	264.7

RECONNECTION TIMES			
	Under/Over voltage	Under/Over Frequency	Loss of Main
Minimum Value Limit [s]	60	60	60
Actual setting [s]	60	60	60
Recorded value [s]	77	81	78

LOSS OF MAIN TESTS			
Method used	Current Pulse for Impedance measurement and Active Power Variation		
Output power Level	10%Prated	55%Prated	100%Prated
BELGIUM C10/11 110% Limit [s]	5.0	5.0	5.0
Trip setting [s]	5.0	5.0	5.0
Trip value [s]	1.4	1.4	1.2

### SSEG Short Circuit Current Contribution Test

RMS Value over 1 Period (Cycle)	11.70	[Aac]
Peak Current	89.3	[A]

### SELF MONITORING – SOLID STATE SWITCHING

Not applicable because electro-mechanical relays are used

### ACCURACY

Voltage reading accuracy = +/- 1%  
 Frequency reading accuracy = +/- 0.05Hz