



**ASA**

Australian Safety Approval\*

**CERTIFICATE OF SUITABILITY**

**ADDENDUM**

**Product:** PV and Wind Grid Tied Inverters  
**Brand Name:** Aurora

**Model Number:** UNO-2.5-I-OUTD-S

**Ratings:** **Input:** 90-520Vdc, dc, 12.8A, IP65  
**Output:** 230Vac, 50Hz, 12.5A, 2500W

**General Modification:** Nil

**Additional Models:**

UNO-2.5-I-OUTD  
 UNO-2.5-I-OUTD-W

UNO-2.0-I-OUTD-S

UNO-2.0-I-OUTD

UNO-2.0-I-OUTD-W

**Description:**

Similar to UNO-2.5-I-OUTD-S without additional DC main switch.  
 Similar to UNO-2.5-I-OUTD-S with Wind source in lieu of PV, alternative software control, ground fault circuit, DC terminal block and optional alternative logic board ZGN.V1004.1

Similar to UNO-2.5-I-OUTD-S with rated input: 12.5A, Rated Output: 10.5A, 2000W

Similar to UNO-2.5-I-OUTD-S with rated input: 12.5A, Rated Output: 10.5A, 2000W, no additional DC main switch.

Similar to UNO-2.5-I-OUTD-S with rated input: 12.5A, Rated Output: 10.5A, 2000W, Wind source in lieu of PV, alternative software control, ground fault c'ct, DC terminal block and optional alternative logic board ZGN.V1004.1

**Date of Modification:** 31 October 2012

**Date of Expiry:** 30 October 2017

For and on Behalf of Australian Safety Approval



\* ASA Electrical Product Safety Certification Scheme.  
 Refer to original Certificate for compliance details.

**JAS-ANZ**



[www.jas-anz.org/register](http://www.jas-anz.org/register)