

Certificate No:12101701/00



Australian Safety Approval

CERTIFICATE OF SUITABILITY

Power-One Energy Solutions Pty Ltd
3/4 Avenue of Americas
Newington, NSW, 2127
Australia

Class	Non Declared
Product:	PV and Wind Grid Tied Inverters
Brand Name:	Aurora
Model Number:	UNO-2.5-I-OUTD-S
Ratings:	Input: 90-520Vdc, dc, 12.8A, IP65 Output: 230Vac, 50Hz, 12.5A, 2500W
Standard:	AS 4777.3-2005 AS 4777.2-2005 AS/NZS 3100:2009 + A1 AS/NZS60950.1:2011
Approval Mark:	ASA12101701
Date of Approval:	31 October 2012
Date of Expiry:	30 October 2017

For and on Behalf of Australian Safety Approval



ASA Electrical Product Safety Certification Scheme confirms, in accordance with ISO/IEC Guide 65, that the electrical product described above complied with the minimum safety standards listed. This Certificate does not confirm that the described equipment complies with claims of Performance.

JAS-ANZ



www.jas-anz.org/register